



June 16, 2010

Mr. Con Mims, Chair
South Central Texas Regional Water Planning Group
% San Antonio River Authority
P.O. Box 839980
San Antonio, TX 78283-9980

RE: City of Cibolo – Comments on SCTRWPG Initially Prepared Plan


Dear Mr. Mims:

The purpose of this letter is to provide the following three comments on the 2011 Initial Prepared Plan (IPP) for the South Central Regional Water Planning Group:

1. The City requests that the following Wholesale Water Provider be included in Table 4.B.2.11-2.
 - a. Springs Hill WSC – 2,000 ac-ft per year beginning in Year 2020
2. The City requests that the description of the CRWA Wells Ranch Water Management be corrected to reflect the actual status of the project. The description in the IPP states: “The infrastructure for Phase 1, including transmission facilities, for the entire 11,000 ac-ft per year has been constructed...Cost estimates for this project assume that Phase 1 is complete.” This description is incorrect. There are two pipeline segments that have not been constructed:
 - a. As shown in Figure 1, there is an 11 mile segment of pipeline that has not been constructed. This segment is necessary to convey water between the Springs Hill WSC Hickory Forest Elevated Storage Facility and the Springs Hill WSC Mesquite Pass Elevated Water Storage Facility;
 - b. As shown in Figure 2, there is a 5.25 mile segment of pipeline that has not been constructed. This segment of pipe is necessary to convey water from IH 10 to the Wagner Booster Station so that it is available to the City of Cibolo.
3. The City requests that both of these pipeline segments be oversized to carry both the CRWA Wells Ranch demands (Bexar and Guadalupe Counties) and the San Jose Water demands (Comal County) and that the oversizing of the pipeline be financed by the TWDB State Participation Program.

Please call me if you need any additional information.

Yours truly,


Rudolph F. Klein IV, P.E., City Engineer
City of Cibolo