

# ***2011 South Central Texas Regional Water Plan***

## **Study 3 – Condensate Collection**

### **Status Report**

**South Central Texas Regional Water Planning Group**

**August 7, 2008**

## ***Study 3 – Task 2: Condensate Collection***

- Prepare preliminary cost estimates to install air-conditioning systems with condensate collection facilities and plumbing to deliver the water for use either as landscape irrigation or for other uses, such as toilet flushing and sanitation.***

# ***Topics for Discussion***


- ☐ Data Available**
- ☐ Correlation Equation Development**
- ☐ Cost Estimates**
- ☐ Potential Concerns**

# Condensation Collection Facility Data

Condensate Collection Project	Location	Building Area (ft <sup>2</sup> )	Average Summer Afternoon Humidity	Average High Summer Temperature (degrees F)	Annual Condensate Recovery Volume (gal/yr)
Sea World Game Center	San Antonio, TX	28,000	57%	91	140,000
Houston EPA Laboratory	Houston, TX	39,408	62%	88	138,333
EPA Gulf Ecology Division Laboratories	Gulf Breeze, FL	79,450	62%	85	100,000
Emory University Winship Cancer Institute	Atlanta, GA	200,000	57%	80	900,000
Fulton County Health Center	Wauseon, OH	281,500	56%	73	353,000
Duke University Gross Chemistry Center and Levine Science Resource Center	Durham, NC	430,000	57%	80	7,000,000

# Condensate Volume vs Area, Humidity, & Temperature

$$\text{Condensate Volume} = (33.3 * \text{Area}) + (21,273,464.4 * \text{Humidity}) + (436,169.7 * \text{Temperature}) - 52,778,292.9$$



## ***Cost Estimates***

- ❑ **Very limited data available on costs for new construction installation**
  - **~\$45,000 in Capital Costs for a 200,000 sq ft facility and included piping to cooling towers only**
- ❑ **Hypothetical “Big Box” store in Bexar County**
  - **130,000 sq ft Example**
  - **Could produce about 11 acft/yr of water, of which about 5 acft/yr could be used on-site (additional costs necessary for storage, plumbing, and/or connection to other potential users)**
- ❑ **Assuming information above and amortizing over 30 years, Unit costs = ~\$950/acft/yr**

# ***Potential Concerns***

## **☐ Dust and Algae Problems**

- Clogged Drains**
- Condensation Pump Motor Failure**
- Overflows**
- Quality problems with collected water**
- Potential risk of mold problems**

**☐ Reduces peak water use, but not a conventional firm supply as air condition use is limited in cooler months (November – March)**